



LEWIS UNIVERSITY POLICE DEPARTMENT

Clery Act Public Crime Log

From 6/1/2016 To 6/30/2016

Incident Type:	POLICE : 7100 SERVICE OTHER AGENCY : 7113 CITY/VILLAGE FIRE DEPARTMENT		
Location:	LEWIS MAIN CAMPUS : CAMPUS BUILDINGS : RESIDENCE HALLS : SOUTH HALL : SH-423 KITCHEN		
Date/Time Reported:	6/19/2016 0800	Incident Occurred Between:	6/19/2016 0759 and 6/19/2016 0800
Case #:	CR16-000147	Int. Ref. #:	Disposition: ADMINISTRATIVELY CLOSED - NO FURTHER INVESTIGATION
Notes:	Fire alarm caused by smoke detector activation due to burnt food in the fourth floor kitchen area.		

Incident Type:	POLICE : 7300 PUBLIC COMPLAINT : 7316 ALARM (FIRE)		
Location:	LEWIS MAIN CAMPUS : CAMPUS BUILDINGS : RESIDENCE HALLS : SOUTH HALL : SH-423 KITCHEN		
Date/Time Reported:	6/19/2016 0800	Incident Occurred Between:	6/19/2016 0759 and 6/19/2016 0800
Case #:	CR16-000147	Int. Ref. #:	Disposition: ADMINISTRATIVELY CLOSED - NO FURTHER INVESTIGATION
Notes:	Fire alarm caused by smoke detector activation due to burnt food in the fourth floor kitchen area.		

Incident Type:

Location:

Incident Type: POLICE : 7300 PUBLIC COMPLAINT : 7316 ALARM (FIRE)
Location: LEWIS MAIN CAMPUS : CAMPUS BUILDINGS : RESIDENCE HALLS : POPE JOHN PAUL II HALL

Date/Time Reported: 6/30/2016 1353 **Incident Occurred Between:** 6/30/2016 1353 and 6/30/2016 1353
Case #: CR16-000151 **Int. Ref. #:** **Disposition:** ADMINISTRATIVELY CLOSED - NO FURTHER INVESTIGATION

Notes: Fire alarm activated in Pope John Paul Hall do to defective riser pump valve.

Incident Type: POLICE : 7100 SERVICE OTHER AGENCY : 7113 CITY/VILLAGE FIRE DEPARTMENT
Location: LEWIS MAIN CAMPUS : CAMPUS BUILDINGS : RESIDENCE HALLS : POPE JOHN PAUL II HALL

Date/Time Reported: 6/30/2016 1353 **Incident Occurred Between:** 6/30/2016 1353 and 6/30/2016 1353
Case #: CR16-000151 **Int. Ref. #:** **Disposition:** ADMINISTRATIVELY CLOSED - NO FURTHER INVESTIGATION

Notes: Fire alarm activated in Pope John Paul Hall do to defective riser pump valve.